

Unit 1

Date & Time	IC(A)	IC(B)	CCS(B) torus cooling	CCS(A) torus cooling	DDFP	Fire Truck (fresh water)	Fire Truck (sea water)
2011/3/11 12:00	0	0	0	0	0	0	0
2011/3/11 14:52	0	0	0	0	0	0	0
2011/3/11 14:52	1	1	0	0	0	0	0
2011/3/11 15:03	1	1	0	0	0	0	0
2011/3/11 15:03	0	0	0	0	0	0	0
2011/3/11 15:05	0	0	0	0	0	0	0
2011/3/11 15:05	0	0	1	0	0	0	0
2011/3/11 15:11	0	0	1	0	0	0	0
2011/3/11 15:11	0	0	1	1	0	0	0
2011/3/11 15:17	0	0	1	1	0	0	0
2011/3/11 15:17	1	0	1	1	0	0	0
2011/3/11 15:19	1	0	1	1	0	0	0
2011/3/11 15:19	0	0	1	1	0	0	0
2011/3/11 15:24	0	0	1	1	0	0	0
2011/3/11 15:24	1	0	1	1	0	0	0
2011/3/11 15:26	1	0	1	1	0	0	0
2011/3/11 15:26	0	0	1	1	0	0	0
2011/3/11 15:32	0	0	1	1	0	0	0
2011/3/11 15:32	1	0	1	1	0	0	0
2011/3/11 15:34	1	0	1	1	0	0	0
2011/3/11 15:34	0	0	1	1	0	0	0
2011/3/11 15:37	0	0	1	1	0	0	0
2011/3/11 15:37	0	0	0	0	0	0	0
2011/3/11 18:18	0	0	0	0	0	0	0
2011/3/11 18:18	1	0	0	0	0	0	0
2011/3/11 18:25	1	0	0	0	0	0	0
2011/3/11 18:25	0	0	0	0	0	0	0
2011/3/11 20:50	0	0	0	0	0	0	0
2011/3/11 20:50	0	0	0	0	1	0	0
2011/3/11 21:30	0	0	0	0	1	0	0
2011/3/11 21:30	1	0	0	0	1	0	0
2011/3/12 1:25	1	0	0	0	1	0	0
2011/3/12 1:25	1	0	0	0	0	0	0
2011/3/12 4:00	1	0	0	0	0	0	0
2011/3/12 4:00	1	0	0	0	0	1	0
2011/3/12 4:00	1	0	0	0	0	0	0
2011/3/12 5:46	1	0	0	0	0	0	0
2011/3/12 5:46	1	0	0	0	0	1	0
2011/3/12 14:53	1	0	0	0	0	1	0
2011/3/12 14:53	1	0	0	0	0	0	0
2011/3/12 19:04	1	0	0	0	0	0	0
2011/3/12 19:04	1	0	0	0	0	0	1
2011/3/12 21:45	1	0	0	0	0	0	1
2011/3/12 21:45	1	0	0	0	0	0	0
2011/3/12 23:50	1	0	0	0	0	0	0
2011/3/12 23:50	1	0	0	0	0	0	1
2011/3/14 1:10	1	0	0	0	0	0	1
2011/3/14 1:10	1	0	0	0	0	0	0
2011/3/14 20:00	1	0	0	0	0	0	0
2011/3/14 20:00	1	0	0	0	0	0	1
2011/3/17	1	0	0	0	0	0	1

in service  
out of service

Unit 1

※Opening operation of IC(A) 3A valve was conducted at 18:18 and 21:30 on March 11, though whether in-containment valves of IC(A) were open or close is unclear.

